



GENERAL NOTES

- 3KW/M² CONTOURS ARE TAKEN INTO ACCOUNT AS SAFE DISTANCE TOWARDS A FIRE.
- TIE-IN WILL BE IN WESTSIDE, BUT EXACT LOCATION IS ON HOLD
- ALL HYDRANTS HAVE A CAPACITY OF 120m³/h
- MAIN RING: HDPE, 8"
- BRANCHES: HDPE, 6"
- ONE WORKING/ONE SPARE DIESEL PUMP IS FORESEEN.
- THE DIESEL PUMPS ARE PLACED IN SMALL BUILDING TO AVOID FREEZING.

NOTES

1. SPLASH SCREEN.
- ASSUMPTION:**
- RESPONSE TIME OF FIREBRIGADE FALCK IN 3 MIN.
 - FOAM WILL BE PROVIDED BY FIREBRIGADE.
- ON EACH LEVEL IN THE PROCESS AREA 2 SAFETY SHOWERS ARE FORESEEN.
THE EXACT LOCATIONS FOR SAFETY SHOWERS WILL BE DEFINED IN DETAILED PHASE.

LEGEND OF SYMBOLS AND ABBREVIATIONS

- FIRE WATER NETWORK
- (H) FIRE HYDRANT
- X SECTION VALVE
- SS SAFETY SHOWER

REV. NO.	REVISION DESCRIPTION	MPU	DRW	CHK	APPROVED	DATE
A	FOR CLIENT COMMENTS					11/03/20

THIS DRAWING AND/OR ITS CONTENTS, INFORMATION, AND PRINCIPLES OF DESIGN ARE THE EXCLUSIVE PROPERTY OF WORLEY BELGIUM BVBA AND IS SUBMITTED TO YOU WITH THE AGREEMENT THAT IT IS NOT TO BE REPRODUCED IN ANY MANNER, COPIED, OR MODIFIED, NOR IS IT TO BE RELAYED IN PART OR IN WHOLE TO ANY OTHER FIRM OR INDIVIDUAL FOR ANY OTHER PROJECT EXCEPT BY WRITTEN AGREEMENT WITH WORLEY BELGIUM BVBA. ACCEPTANCE OF THIS DRAWING WILL BE CONSTRUED AS AN AGREEMENT TO THIS STATEMENT.



WORLEY BELGIUM BVBA
NOORDERLAAN 127, 2030 ANTWERP,
BELGIUM

ARP PROJECT MONDEGO - ISBL

PROJ. NO.	DRAWING NO.	REV		
BB001501	FIRE WATER NETWORK ARRANGEMENT	A		
DATE	FILE NAME	DRAWING SCALE	PLOT SCALE	DRAWN BY
11-03-2020	BB001501/0101/2020	1:400 on A1	1:1	MPU